

SIEMENS

PRODUCT RECALL

Siemens plug-in type QP circuit breakers and X-Press Pack loadcentres

Home Owners / Contractors / Distributors / Retailers

Siemens Canada Limited has recently issued a safety notice / product recall on selected one and two pole, plug-in type “QP” circuit breakers and X-Press packs loadcentres. The breakers affected are those manufactured in Mexico with a black label on the face of the breaker and with following model numbers, carrying date codes **0610** and **0710**:

**Model numbers:
Q115, Q120, Q130,
Q215, Q230 and Q250**



The X-Press Pack loadcentres affected are all model numbers starting with “XP” sold in the months of June, July and August 2010.

Distributors & Electrical Contractors & End Users/Home Owners:
Please contact our hotline at **1-888-557-5588** or visit our website **www.siemens.ca/breakerrecall** for more details on how to identify the products and how to go about getting them replaced.

Siemens Canada Limited is committed to provide our customers with safe and quality products. We regret any inconvenience this issue may cause.

Recall Hotline: 1-888-557-5588 • Recall Fax: 1-905-335-3098
Recall Email: q.recall.ca@siemens.com
Recall Website: www.siemens.ca/breakerrecall